


# OZONE GENERATOR PERFORMANCE TEST

TG-300 Ozone Generator – Water Cooled Ozone Generator


#1

# #	Oxygen Flow in LPM	Ozone Concentration, % by weight	Ozone Production in g/hr	PSI	COMMENTS
1	20.00	8.20	140.71	20	
2	40.00	6.90	236.81	20	
3	60.00	5.80	298.58	20	
4	80.00	5.00	343.20	20	
5	100.00	4.20	360.36	20	

**Ozone Concentration**



**Ozone Production**



Test was performed at 72°F, Generator was ON for more than 1 hour.  
Ozone Analyzer API 460H