


OZONE GENERATOR PERFORMANCE TEST

TG-450 Ozone Generator – Water Cooled Ozone Generator


#1

# #	Oxygen Flow in LPM	Ozone Concentration, % by weight	Ozone Production in g/hr	PSI	COMMENTS
1	30.00	8.20	211.07	20	
2	60.00	6.90	355.21	20	
3	90.00	5.80	447.88	20	
4	120.00	5.00	514.80	20	
5	150.00	4.20	540.54	20	

Ozone Concentration



Ozone Production



Test was performed at 72°F, Generator was ON for more than 1 hour.
Ozone Analyzer API 460H